

**SECTION 00900
ADDENDUM**

GENERAL

1.01 The following sets forth the format for issued Addenda.

ADDENDUM NO. 3, dated October 21, 2009.

RE: Barnwell ES – Addition & Renovation

FROM: OWNER: FULTON COUNTY BOARD OF EDUCATION
CAPITAL PROGRAM CONTRACTS DEPARTMENT
THE MEADOWS OPERATION CENTER
5270 Northfield Boulevard
College Park, GA 30349



Architect/Engineer Stamp & Signature

TO: ALL PROSPECTIVE BIDDERS:

This Addendum forms a part of the Contract Documents and modifies the Proposal Documents dated July 20, 2009, as noted below. Acknowledge receipt of the Addendum in the space provided on Document 00400 - Proposal Acceptance Form. Failure to do so may result in the proposal being deemed non-responsive.

The Addendum consists of two pages, and the attached drawing, Sheet No. C114 with the revised date of 10-20-09.

A. CHANGES TO PROPOSAL REQUIREMENTS TABLE OF CONTENTS: None.

B. CHANGES TO PRIOR ADDENDUM:

1. Addendum No. 2: Item F., Number 8: The letter "E" was left out of the Sheet Number. The correct reading of the Sheet Number is "E102".
2. Addendum No. 2: Item F.: The description of changes to Sheet M102 was left out of the Addendum. Add Number 10. to this Item F. as follows: "SHEET M102; HVAC: This Sheet is revised as shown by clouded outline indicated as "A2" and was attached to the previously issued Addendum No. 2. Changes indicate ducted return for WSHP-209, outside air to corridor units, and upsized outside air duct from 22x14 to 22x16. Changes indicate upsized outside air duct serving Level 100 from 16x12 to 16x14, increased exhaust duct from 20x14 to 20x16, and added exhaust grille within the corridor to provide additional relief due to increased outside air.

C. CHANGES TO PROPOSAL DOCUMENTS:

1. SECTION 00410; PROPOSAL SECURITY FORM: Delete existing Section 00410 and add new Section 00410 "Proposal Security Form" attached to this Addendum.

D. CHANGES TO CONDITIONS OF THE CONTRACT: None.

E. CHANGES TO SPECIFICATIONS:

1. SECTION 05600; PREFABRICATED METAL PRODUCTS: 1.01, C., 3.: Delete.
2. SECTION 07410; MANUFACTURED ROOF AND WALL PANELS: 2.01, A.: Add MBCI Metal Roof & Wall Systems; Super Lok roofing panel.
3. SECTION 08710; DOOR HARDWARE: Finish Hardware Schedule: Add Hardware Set 06 as follows:
HW SET: 06
Door Number: 005F
EACH TO HAVE:
6 HINGES 5BB1HW IVE
1 MULLION KR9954 VON

2	FIRE EXIT DEVICE	98L-F-BE X 499 X SNB	VON
2	SURFACE CLOSER	4111 EDA X MC x SNB	LCN
2	KICK PLATE	8400	IVE
1	SET SEALS	5020	NGP

4. SECTION 10120; TACKBOARDS: 1.02, A. Add Newline Products, Inc.
5. SECTION 10130; MARKERBOARDS: 2.01, A., 1.: Add Newline Products, Inc.
6. SECTION 10670; STORAGE SHELVING: Sub-Part 2.02: Delete.

F. CHANGES TO DRAWINGS:

1. SHEET C114; CONSTRUCTION DETAILS: This Sheet is revised as shown by clouded outline indicated as "A3" and is attached to this Addendum. This includes a heavy duty pavement section.

G. OTHER CHANGES AS SET FORTH:

1. CLARIFICATION: Do not use the architectural plans for referencing kitchen equipment. See the K series drawings for all kitchen equipment placement and number referencing.
2. CLARIFICATION: On sheet C106A - Enlarged Site Plan, No header curb is shown or required at the new asphalt drive/fire lane adjacent to the new addition after the 24" curb and gutter terminates.
3. CLARIFICATION: Sheet A102: Main Level Floor Plan Classroom Addition: There are three type A (36"Wx84"Hx12"D), and two type B shelves (36"Wx84"Hx24"D) in Custodial & Storage rooms 128 & 226. These shelves are specified in Section 10670 "Storage Shelving".
4. CLARIFICATION: Sheet A103: Main Level Floor Plan Cafeteria Addition: Electrical Room 303 is finish type A. Storage room 304 is finish type A. See finish schedule for descriptions shown in the border of sheet A103.
5. CLARIFICATION: No sod is proposed. Please seed all disturbed areas (DS3) per Sheet C109. The seed specification (for permanent grassing) is noted on Sheet TP-1.

Clarification or any other notice of a change in the Proposal Documents will be issued only by the OWNER Contracts Department and only in the form of a written Addendum, transmitted by fax or e-mail to all who are known by the issuing office to have received a complete set of PROPOSAL Documents. Any other purported Addenda are void and unenforceable.

END OF ADDENDUM NO. 3